

Environment Act Licence Loi sur l'environnement Licence

Manitoba
Environment
Environnement
Manitoba



Licence No./Licence n° 2236 S1
Issue Date/Date de délivrance December 5, 1996

In accordance with the Manitoba Environment Act (C.C.S.M. c. E125)

THIS LICENCE IS ISSUED TO:

MIDDLECHURCH HOME OF WINNIPEG: "the Licencee" STAGE 1 LICENCE

for the construction and operation of the Development being a modified wastewater collection system and a new pre-treatment facility (flow equalization tank) located at 28 Balderstone Road, River Lot 18 in the Rural Municipality of West St. Paul in accordance with the Proposal filed under The Environment Act on September 10, 1996 and subject to the following terms and conditions:

GENERAL TERMS AND CONDITIONS

This Section of the Licence contains terms and conditions intended to provide guidance to the Licencee in implementing practices to ensure that the environment is maintained in such a manner as to sustain a high quality of life, including social and economic development, recreation and leisure for present and future Manitobans.

1. The Licencee shall ensure that the internal wastewater collection system diverts the backwash water from the softeners to the effluent outfall pipe.
2. The Licencee shall ensure that the existing pre-treatment facility is decommissioned and removed from the site.
3. The Licencee shall, as deemed necessary by the Director, carry out any remedial measures or modifications in respect to matters authorized under this Licence.

SPECIFICATIONS, LIMITS, TERMS AND CONDITIONS

4. The Licencee shall ensure that the proposed pre-treatment facility has a hydraulic capacity of not less than 59 m³ and that the facility is constructed with one manhole consisting of two access hatches to provide access to the tank and for maintenance purposes.
5. The Licencee shall ensure that the pre-treatment system is designed on the basis of a maximum hourly flow to the wastewater treatment plant.

6. The Licencee shall ensure that the pre-aeration system is capable of providing a minimum capacity of air of 0.14 litres/sec per m³ of tank storage capacity for mixing and minimizing odours.

REVIEW AND REVOCATION

- A. If, in the opinion of the Director, the Licencee has exceeded or are exceeding or has or are failing to meet the specifications, limits, terms, or conditions set out in this Licence, the Director may, temporarily or permanently, revoke this Licence.
- B. If the Licencee has not commenced construction of the Development within one year of the date of this Licence, the Licence is revoked.
- C. If, in the opinion of the Director, new evidence warrants a change in the specifications, limits, terms or conditions of this Licence, the Director may require the filing of a new proposal pursuant to Section 11 of the Environment Act.



Larry Strachan, P. Eng.
Director
Environment Act