

COPY

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION  
UNDER THE CLEAN ENVIRONMENT ACT

---

RE: THE CLEAN ENVIRONMENT COMMISSION and THE VILLAGE OF ETHELBERT, Applicant,

WHEREAS on the 8th day of April, 1968, the sewage lagoon serving the unincorporated Village of Ethelbert was licenced by The Provincial Sanitary Control Commission under the provisions of the Pollution of Waters Prevention Act;

AND WHEREAS Pursuant to the provisions of The Clean Environment Act, the Village of Ethelbert filed a registration with the department in connection with the operation of a sewage lagoon system located in the SW 1/4 of Section 32, Township 29, Range 21 WPM in the Rural Municipality of Ethelbert, Manitoba, with discharge of effluent to Shanty Creek;

AND WHEREAS in the absence of limits, terms and conditions set by a regulation, the proposal was referred to The Clean Environment Commission to set limits, terms and conditions;

AND WHEREAS after giving notice of its intention to set limits, terms and conditions, the Commission did not receive notice of representation from any person who was likely to be affected;

AND WHEREAS the Commission considered the operation on the 15th day of January, 1988;


IT IS HEREBY ORDERED THAT

1. The Applicant shall not discharge effluent from the said sewage lagoon system
  - (a) where the organic content of the effluent as indicated by the five day biochemical oxygen demand, is in excess of 30 milligrams per litre;
  - (b) where the faecal coliform content of the effluent as indicated by the MPN index, is in excess of 200 per 100 millilitres of sample;

1. (c) where the total coliform content of the effluent as indicated by the MPN index, is in excess of 1500 per 100 millilitres of sample;
- (d) between the 1st day of November of any year and the 15th day of May of the following year.
2. The Applicant shall operate and maintain the said sewage lagoon system in such a manner that:
  - (a) the release of offensive odours is minimized;
  - (b) the organic loading on the primary cell of the said sewage lagoon system, as indicated by the five day biochemical oxygen demand, is not in excess of 56 kilograms per hectare per day.

Order No. 1142

Dated at the City of Winnipeg  
this 18th day of January, 1988.

  
\_\_\_\_\_  
Chairperson,  
The Clean Environment Commission.

File: 181.1