

COPY

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION
UNDER THE CLEAN ENVIRONMENT ACT

RE: THE CLEAN ENVIRONMENT COMMISSION and THE LORD SELKIRK SCHOOL DIVISION
NO. 11, Applicant,

WHEREAS pursuant to the provisions of The Clean Environment Act, the Lord Selkirk School Division No. 11 filed a registration with the department in connection with the operation of a sewage treatment plant and holding pond located in parts of River Lots 104, 105 and 106, Plan 2565 in the Parish of St. Andrews in the Rural Municipality of St. Andrews, Manitoba, serving the Lockport Junior High School with discharge of effluent via ditches to the Red River;

AND WHEREAS in the absence of limits, terms and conditions prescribed by a regulation under the said Act, the registration was referred to The Clean Environment Commission to prescribe limits, terms and conditions;

AND WHEREAS after giving notice of its intention to issue an order prescribing limits, terms and conditions concerning the registration, the Commission did not receive notice of representation from any person who was likely to be affected;

AND WHEREAS the Commission considered the registration on the 15th day of January, 1988;

IT IS HEREBY ORDERED THAT

1. The Applicant shall maintain and operate all facilities for the treatment of sewage and the holding of effluent in such a manner as to prevent the contamination of groundwater.
2. The Applicant shall operate the facilities in such a manner as to minimize the release of offensive odours.

Continued

- 2 -

LORD SELKIRK SCHOOL
DIVISION NO. 11

3. The Applicant shall not discharge effluent to the environment from the said sewage treatment plant or holding pond:
 - (a) where the organic content of the effluent, as indicated by the five day biochemical oxygen demand, is in excess of 30 milligrams per litre;
 - (b) where the total coliform content of the effluent, as indicated by the MPN index, is in excess of 1500 per 100 millilitres of sample;
 - (c) where the fecal coliform content of the effluent, as indicated by the MPN index, is in excess of 200 per 100 millilitres of sample.

4. The Applicant shall not discharge effluent to the environment from the said sewage treatment plant or holding pond
 - (a) between the 1st day of November in any year and the 1st day of May in the following year;
 - (b) from the 15th day of June to the 1st day of October in any year;
 - (c) where the effluent will cause or contribute to flood along the discharge route.

Order No. 1150

Dated at the City of Winnipeg

this 19th day of January, 1988.


Chairperson,
The Clean Environment Commission.

File: 1740.0