



ja.

304 - 401 YORK AVE., WINNIPEG R3C 0P8
TELEPHONE 948-7802

March 13th, 1972

158

ORDINARY LICENCE - MANITOBA HYDRO
PINE FALLS GENERATING STATION
Local Government District of Alexander

This licence is issued pursuant to The Clean Environment Act permitting Manitoba Hydro to discharge contaminants or wastes arising from the operation of a septic tank located at the Pine Falls Generating Station in the Local Government District of Alexander, into the Winnipeg River, subject to the following conditions:

- 1) The licensee shall ensure that the contaminants or wastes thus collected and retained in the said septic tank are chlorinated to a residual of 0.5 milligrams per litre after 15 minutes contact before release of the effluent takes place to the Winnipeg River.
- 2) The licensee shall ensure that the said septic tank is not used by more than 15 persons within any one day.
- 3) The licensee shall ensure that the said septic tank be cleaned when required and at least once yearly and that the sludge be disposed of in a manner approved by the Clean Environment Commission.

Chairman,
CLEAN ENVIRONMENT COMMISSION.

*sent opp -
amended to
sent opp
19 April 72
WMMW*