

282
m.d.

AN ORDER OF THE CLEAN ENVIRONMENT COMMISSION
UNDER THE CLEAN ENVIRONMENT ACT

GRA

Re: The Clean Environment Commission and Frontier School Division, applicant,

WHEREAS pursuant to the provisions of The Clean Environment Act, the Frontier School Division has submitted an application to the Clean Environment Commission to prescribe limits in connection with the operation of a mechanical sewage treatment plant located at the Grand Rapids School, Block 11, Plan 784 in the Local Government District of Grand Rapids with effluent discharge into the Saskatchewan River,

AND WHEREAS no representation was made to the Clean Environment Commission by any person who is or is likely to be affected by an Order of the Commission prescribing limits in connection with said operation,

AND WHEREAS the Clean Environment Commission considered the application on the 14th day of May 1973,


IT IS HEREBY ORDERED THAT

1. The applicant shall ensure that the said facility is constructed, maintained and operated in such a manner as to prevent contamination of groundwater,
2. The applicant shall ensure that the said facility is operated in such a manner as to minimize the release of offensive odours,
3. The applicant shall ensure that the biochemical oxygen demand loading of the said facility does not exceed 30 pounds per day,
4. The applicant shall ensure that the effluent of the said facility is chlorinated to a chlorine residual of 0.5 millilitres per litre after fifteen minutes contact,
5. The applicant shall ensure that the biochemical oxygen demand of the effluent of the said facility does not exceed 30 milligrams per liter.

*Assigned to
Cory Opa
June 6/73*

Order No. 282

Dated at this City of Winnipeg
this 25th day of May 1973



Chairman,
Clean Environment Commission
cc: Regional Series