



Sustainable Development

Environmental Stewardship Division
Environmental Approvals Branch
123 Main Street, Suite 160, Winnipeg Manitoba R3C 1A5
T 204 945-8321 F 204-945-5229
www.gov.mb.ca/conservation/eal

File: 1921.10

November 7, 2016

Daryl Hrehirchuk, CAO
R.M. of MacDonald
Box 100
Sanford MB R0G 2J0

Dear Mr. Daryl Hrehirchuk:

Re: Community of Sanford Wastewater Treatment Lagoon Expansion – New Secondary Cell # 2 Liner

This is further to liner installation reports from AMEC Foster Wheeler relative to the recently constructed Secondary Cell # 2 at the Rural Municipality of MacDonald's (Sanford) wastewater treatment lagoon. The reports were submitted by Mr. Dana Bredin, P.Eng. of WSP Canada Inc. on October 7, 2016. Environment Act Licence No. 857 RR (Licence) applies to this lagoon.

The test results indicate that the soil liner of the Secondary Cell # 2 of the lagoon meets the requirements of Clause 19 c) of the Licence regarding hydraulic conductivity. Authorization to operate the above mentioned cell of the lagoon is provided pursuant to Clause 41 of the Licence. Record drawings for the facility are due within four months of the date of this letter (by March 7, 2017) as required by Clause 43 of the Licence.

If you have any questions regarding this matter, please contact me at (204) 945-2614 or at asit.dey@gov.mb.ca.

Yours sincerely,

“original signed by”

Asit Dey, P. Eng.
Environmental Engineer

c: Dana Bredin, P.Eng., WSP Canada Inc.
Don Labossiere/Donna Smiley/Yvonne Hawryliuk, Environmental Compliance and Enforcement Branch
Public Registries