

Webb, Bruce (CWS)

Subject: FW: Beausejour Lagoon Expansion EAP
Attachments: Lagoon Plan for Licence.pdf

From: Brett McCormac [<mailto:bmccormac@jrcc.ca>]
Sent: March-24-14 1:58 PM
To: Webb, Bruce (CWS)
Cc: 'Jack Douglas'; 'TJ Schatkowsky'; Jerry Cousin
Subject: RE: Beausejour Lagoon Expansion EAP

Hi Bruce,

As discussed on the phone this morning, attached is a revised plan of the Town of Beausejour lagoon expansion cells. The revised layout will have only 2 new cells (Cell 7 and Cell 8). Each cell will have a flat bottom area of 310 m x 315 m for a combined volume of 245,300 m³ (slightly more than the old layout of 244,600 m³).

If you require anything else, please contact me.

Brett McCormac, E.I.T.
Environmental Engineer-in-Training

J.R. Cousin Consultants Ltd.
Phone: (204) 489-0474
Fax: (204) 489-0487
www.ircc.ca

The information contained in this email and any attachments is privileged, confidential and subject to copyright. It is intended solely for the use of the person(s) to whom it is addressed. If you receive this email in error, please notify the sender by return email and permanently delete it from your system. Note: We have taken precautions against viruses, but take no responsibility for loss or damage caused by any virus present.



NW1/4 12-13-07-E

NE1/4 12-13-07-E

PROPOSED
PROPERTY LINE

STORAGE
CELL #8

STORAGE
CELL #6

SW1/4 12-13-07-E

STORAGE
CELL #7

SE1/4 12-13-07-E

P.T.H. 12/44

#3

#4

PRIMARY CELLS

#2

#1

STORAGE
CELL #5

