



Sustainable Development

Environmental Stewardship Division
Environmental Approvals Branch
123 Main Street, Suite 160, Winnipeg Manitoba R3C 1A5
T 204 945-8321 F 204-945-5229
www.gov.mb.ca/conservation/eal

File: 4482.10

November 3, 2016

Christine Hutlet, CAO
R.M. of Tache
Box 100, 1294 Dawson Road
Lorette, MB R0A 0Y0

Dear Ms. Christine Hutlet:

Re: Community of Lorette Aerated Wastewater Treatment Lagoon Expansion – New Primary and Secondary Cell Liner

This is further to liner installation reports from Eng-Tech Consulting Limited completed on October 11, 21, and 28 of 2016 relative to the recently constructed Primary Cell # 1 (aerated) and Secondary Cell # 3 at the Rural Municipality of Tache's (Lorette) wastewater treatment lagoon. The reports were submitted by Jason Bunn, P.Eng. of WSP Canada Inc. on October 11, 25, and 31 of 2016. Environment Act Licence No. 2439 RR (Licence) applies to this lagoon. An interim authorization to operate the Primary Cell # 1 was provided on October 13, 2016.

The test results indicate that the soil liners of the Primary Cell # 1 and the Secondary Cell # 3 of the lagoon meet the requirements of Clause 19 c) of the Licence regarding hydraulic conductivity. Authorization to operate the above mentioned cells of the lagoon is provided pursuant to Clause 45 of the Licence. Record drawings for the facility are due within four months of the date of this letter (by March 3, 2017) as required by Clause 48 of the Licence.

If you have any questions regarding this matter, please contact me at (204) 945-2614 or at asit.dey@gov.mb.ca.

Yours sincerely,

“original signed by”

Asit Dey, P. Eng.
Environmental Engineer

c: Jason Bunn, P.Eng., WSP Canada Inc.
Don Labossiere/Donna Smiley/Diane Oertel, Environmental Compliance and Enforcement
Branch
Public Registries