

12 Aviation Boulevard
St. Andrews, Manitoba R1A 3N5
Canada
Tel: (204) 334-8846 Fax: (204) 334-6965
E-mail: dgh@dghengineering.com

October 15, 2014
Rafiqul Chowdhury, M.Eng., P.Eng.
Manitoba Conservation and Water Stewardship
Suite 160, 123 Main Street
Winnipeg, Manitoba, R3C 1A5

Dear Mr. Chowdhury:

Re: Rock Lake Holding Ltd. – Wastewater Treatment Lagoon – Environment Act Proposal (File: 5059.00)

This is in response to your letter dated April 12, and your e-mail dated April 25, 2013. Upon your request, responses to each individual requestor were prepared. Please find attached.

Should you have any questions or need any further information, please feel free to contact the undersigned.



Respectfully submitted,

DGH Engineering Ltd.

Per

Charles Liu, P.Eng.

cc: Ben Hofer (204-322-5268)
Tracy Braun (tracy.braun@gov.mb.ca)



- 1. Response to the e-mail from Water Stewardship (Mr. Rob Matthews to Mr. Rafiqul Chowdhury, date February 10, 2013)**
Rock Lake Holding Ltd. obtained a water rights licence (#2013-051).
- 2. Response to the e-mail from Manitoba Conservation (Mr. Jonathan Wiens to Mr. Rafiqul Chowdhury, date February 15, 2013)**
The proposed lagoon is to be located approximately 180 metres north of the existing lagoon. The existing lagoon will be decommissioned after the proposed lagoon is in operation. No significant change in attracting geese can be expected from the operation of the proposed lagoon following decommissioning of the existing lagoon.
- 3. Response to the e-mail from Fisher Branch (Mr. Lauren Janusz to Mr. Rafiqul Chowdhury dated February 27, 2013)**
 - A minimum of 15 metres from Colony Creek
The setback shown in the site plan C1 is 50 feet (15.2 metres). Please refer to the drawings.
 - Phosphorous limits
The director will specify discharge effluent limits in the licence. Rock Lake Holding Ltd. will follow the terms, conditions, specifications and limits listed in the licence.
- 4. Response to the e-mail from Concerned Citizens of Grosse Isle (Mr. Bill Massey to Mr. Rafiqul Chowdhury dated March 1, 2013)**
Rock Lake Holding Ltd. appreciates the invitation from the Concerned Citizens of Grosse Isle. Rock Lake Holding Ltd., however, has no plans to connect their domestic wastewater to the Grosse Isle Lagoon.
- 5. Response to the e-mail from Manitoba Conservation Land Branch (Ms. Adara Kaita to Mr. Rafiqul Chowdhury dated March 7, 2013)**
This EAP is filed in accordance with the Manitoba Environment Act (C.C.S.M. c. E125). The director will specify discharge effluent limits in the licence. Rock Lake Holding Ltd. will follow the terms, conditions, specifications and limits listed in the licence.