



Sustainable Development

Environmental Stewardship Division
Environmental Approvals Branch
123 Main Street, Suite 160, Winnipeg, Manitoba, Canada R3C 1A5
T 204 945-8321 F 204-945-5229
www.gov.mb.ca/conservation/eal

File: 5389.00

December 7, 2016

Mr. Tim Waldner
Brightstone Holding Co.
Box 880
Lac du Bonnet MB R0E 1A0
Tim.Waldner@brightstone.xyz

Dear Mr. Waldner:

**Re: Brightstone Colony Wastewater Treatment Lagoon – Liner Approval
Environment Act Licence No. 3019**

This is further to liner test results for the new wastewater treatment lagoon provided by Jason Bunn of WSP on December 2, 2016. The liner's hydraulic conductivity meets the requirements of Clause 15 of the above licence, and so approval to operate the facility is provided pursuant to Clause 18 of the Licence.

Record drawings for the facility are required within four months of the date of this letter as noted in Clause 14 b) of the licence.

In a letter of March 11, 2014 to Jason Bunn, the Director approved a short term alteration to the effluent phosphorus limit in the above licence to allow a trial of a proposed trickle discharge strategy. This alteration to the requirement of Clause 22 e) of the licence applies to the first year of operation of the facility, also referenced as one year after the approval of operation of the facility. For clarity, since the forcemain of the facility will not be installed until the summer of 2017, the approval for the trial trickle discharge strategy will extend for one year after the facility becomes operational, so that a complete fill and discharge cycle can be included in the trial.

If you have any questions regarding these matters, please contact me at Bruce.Webb@gov.mb.ca or by telephone at (204) 945-7021.

Yours sincerely,

Bruce Webb, P. Eng.
Water Development and Control
Assessment Officer

c: Jason Bunn, WSP
Don Labossiere/ Donna Smiley/ Dianne Oertel, Environmental Compliance
and Enforcement Branch
Public Registries