



Conservation and Water Stewardship

Environmental Stewardship Division
Environmental Approvals Branch
1007 Century Street, Winnipeg, Manitoba R3H 0W4
T 204 945-7086 F 204 945-5229
www.gov.mb.ca/conservation/eal

Client File: 5764.00

June 17, 2015

Mr. Dmytri Kandiurin
Town of Churchill
P.O. Box 459
Churchill MB R0B 0E0

Dear Mr. Kandiurin:

Re: TOWN OF CHURCHILL – DGHTA LICENCE PROPOSAL – USED OIL COLLECTION FACILITY - FILE: 5764.00

The initial review of City of Churchill *Dangerous Goods Handling and Transportation Act* (DGH&T Act) proposal for a used oil collection facility has been completed.

I am herewith enclosing the following comments received from the Technical Advisory Committee (TAC) members for your information:

- (a) The Office of the Fire Commissioner and*
- (b) Environmental Compliance & Enforcement Branch, Manitoba Conservation & Water Stewardship*

If you have any questions in this regard, please contact the undersigned at (204) 945-7086 or e mail at raj.rathamano@gov.mb.ca.

Yours truly,

“Original signed by Raj Rathamano”

Raj Rathamano

Hazardous Waste Program Specialist/
Environment Officer

Encl/.

c: Public Registries

Attachment

TOWN OF CHURCHILL – DGHTA LICENCE PROPOSAL – USED OIL COLLECTION FACILITY - FILE: 5764.00

Comment received from the Technical Advisory Committee (TAC) for information

(a) Office of the Fire Commissioner, May 19, 2015

From: Kubish, Cheryl (OFC)

Sent: May-19-15 9:37 AM

To: Rathamano, Raj (CWS)

Subject: RE: Comment and review - DGHTA Applications x 2 for comment - Town of Churchill - Used Oil Space Heater Facility File: 5763.00 AND **Used Oil Collection Facility File: 5764.00**

5764 - The Office of the Fire Commission recommends that an updated Fire Safety Plan be submitted to the Churchill Fire Department for their review. The Office of the Fire Commissioner has no concerns or comments.

Cheryl Kubish
Administrative Assistant
Office of the Fire Commissioner
508-401 York Avenue
Winnipeg MB R3C 0P8
Phone: 945-3328
Fax: 948-2089

E-Mail address: Cheryl.Kubish@gov.mb.ca

(b) Environmental Compliance & Enforcement Branch, Manitoba Conservation & Water Stewardship – May 1, 2015

From: Fountain, Jeff (CWS)
Sent: May-01-15 11:32 AM
To: Rathamano, Raj (CWS)
Cc: Prawdzik, Tim (CWS)
Subject: FW: Comment and review - DGHTA Applications x 2 for comment - Town of Churchill - Used Oil Space Heater Facility File: 5763.00 AND **Used Oil Collection Facility File: 5764.00**

Raj,

I have reviewed the proposal for the waste oil space heater and associated storage in Churchill and have the following comments.

The proposal states:

“Transport of waste oil will be done by a Town of Churchill truck which will have a license to transport hazardous wastes. Transportation will be minimized by this project as only the glycol will be shipped to southern Manitoba instead of both waste oil and glycol.”

I expect that other hazardous wastes are being shipped out and assume this is just an oversight. However, I remind the Town of Churchill that paints, chemicals, many cleaners, fluorescent light bulbs and many other products and materials are considered Hazardous waste and must be shipped to a recognized receiver.

I have no other concerns with respect to the proposal. Recent inspections have demonstrated the extent of the Town of Churchill’s commitment to waste management and the system was impressive. The regional office applauds this new addition to Churchill’s waste management system and is eager to see it in action.

Jeff Fountain
Regional Supervisor
Northeast Region
Environmental Compliance and Enforcement Branch
28-59 Elizabeth Dr.
Thompson MB R8N 1X4
P: (204) 677-6703
F: (204) 677-6888
E: Jeff.Fountain@gov.mb.ca