



Sustainable Development

Environmental Stewardship Division
Environmental Approvals Branch
123 Main Street, Suite 160, Winnipeg Manitoba R3C 1A5
T 204 945-8321 F 204-945-5229
www.gov.mb.ca/conservation/eal

File: 5774.00

January 20, 2017

Chief John Stagg
Dauphin River First Nation
Box 58
Gypsumville MB R0C 1J0

Honourable Chief John Stagg:

Re: Dauphin River First Nation Wastewater Treatment Lagoon – Authorization to Use Primary Cell – Environment Act Licence No. 3160

This is further to liner installation reports from TREK Geotechnical relative to the recently constructed Primary Cell at the Dauphin River First Nation's wastewater treatment lagoon. The reports were submitted by Mr. Jason Cousin, P.Eng. of JR Cousin Consultants Ltd. on January 4, 2017. Environment Act Licence No. 3160 (Licence) applies to this lagoon.

The test results indicate that the soil liner of the Primary Cell of the lagoon meets the requirements of Clause 16 c) of the Licence regarding hydraulic conductivity. Authorization to operate the above mentioned cell of the lagoon is provided pursuant to Clause 19 of the Licence. Authorization to operate the Secondary Cell of the lagoon will only be provided upon receipt of the complete and acceptable liner installation reports for the Secondary Cell.

If you have any questions regarding this matter, please contact me at (204) 945-2614 or at asit.dey@gov.mb.ca.

Yours sincerely,

“original signed by”

Asit Dey, P. Eng.
Environmental Engineer

c: Jason Cousin, P.Eng., JR Cousin Consultants Ltd.
Don Labossiere/Donna Smiley/Mike Baert, Environmental Compliance and Enforcement
Branch
Public Registries