



Environment and Climate
Environmental Approvals Branch
14 Fultz Boulevard (Box 35)
Winnipeg MB R3Y 0L6
T 204-945-8321 F 204-945-5229
EABDirector@gov.mb.ca

File No.: 5786.00

July 25, 2023

Kevin D. Poirier, P.Eng., CSR-P.
Director and Principal Consultant
SCV Consulting Ltd.
kpoirier@scvconsultingltd.com

Dear Kevin Poirier:

Re: Environment Act Licence No. 3158 - Notice of Alteration Approval

Thank you for your notice of alteration dated May 10, 2023. The department understands you wish to install a Gas Energy Mixing system at Lactalis' Winnipeg facility to add supplementary treatment to the process water discharged to the City of Winnipeg's sewer system. This change will increase the removal of fats, oils, and greases (FOGs) and total suspended solids (TSS) from the process wastewater.

I approve the alteration per Section 14(2) of The Environment Act with the following conditions:

- The sludge produced by the Gas Energy Mixing treatment system should be liquid (i.e., sludge solids content must not exceed 7% at any given time).
- This approval letter is to be displayed alongside Environment Act Licence No. 3158 at all times and considered part thereof.

All clauses of Environment Act Licence No. 3158 remain in effect. This approval is available on the public registry at <https://www.gov.mb.ca/sd/eal/registries/index.html>.

If you have any questions regarding this approval, please contact Housseïni Coulibaly, Environmental Approvals Branch, at Housseini.Coulibaly@gov.mb.ca or 431-276-6465.

For questions relating to the ongoing administration of the licence, please contact Sonja Bridges, Acting Regional Supervisor – Winnipeg, Environmental Compliance and Enforcement Branch, at EnvCEWinnipeg@gov.mb.ca or 204-918-4271.

Sincerely,

Original Signed By
Agnes Wittmann
Director
The Environment Act

c. Sonja Bridges