

Checklist: Hauled Water (HAUL)



The Drinking Water Safety Act
Self Assessment or Qualified Person
Checklist

Sustainable Development

Revised: September 18, 2018

Section 1: Owner Information

Owner Water System

Operator Water System

Owner Mailing Address

Town/ City Province Postal Code

Email Phone/ Cell

Section 2: Water System Information

Public Water System (PWS) PWS Code # (i.e. 123.00)

Semi-Public Water System (SPWS) SPWS Code # (i.e. 1000.00)

Operating License # Seasonal? Yes No N/A

Section 3: Assessor Information *(please fill this out even if Self Assessment)*

Name

Company

Email Phone/ Cell

Section 4: Certification

The information contained in this report is complete and accurate to the best of my knowledge.

Signature of Owner or Owner's Representative

Date

Personal information is collected under the authority of *The Drinking Water Safety Act* and its pursuant regulations, and is used to issue permits and licenses, and for enforcement purposes. Information collected is protected by the privacy provisions of *The Freedom of Information and Protection of Privacy Act*. If you have any questions, contact the Access & Privacy Coordinator, 200 Saulteaux Crescent, Box 85, Winnipeg MB, R3J 3W3.

Checklist: Hauled Water (HAUL)

Section 5: System Supplying Hauled Water

Provide the water system code # of the system supplying the hauled water.

Public Water System (PWS) PWS Code # (i.e. 123.00)

Semi-Public Water System (SPWS) SPWS Code # (i.e. 1000.00)

Attachments

Section 6: Suggestions or Recommendations for Improvements *(please don't leave blank)*

Checklist: Hauled Water (HAUL)

Section 7: HAUL System - Description

Type of Water System Connections: Hospital/ Health Care Centre Apartments/ Condos
 Year-round Residential Restaurant/ Food Establish. Day Care Facility
 Seasonal Cottages School Rec./ Community Centre
 RV Hook-ups Personal Care Home Other:
 Open Campsites/ Standpipes Seniors Manor/ Apartments

Average # People Served per Day

Peak # People Served per Day

Building or Service Connections (include standpipes)

WATER USE: PROVIDE UNITS! (volume water/ time) i.e. Liters, cubic meters, US or Imperial gallons.

Average Day Demand
 Metered Estimated

Don't just write "gallons".
1 US gallon = 3.785 L
1 Imp gallon = 4.546 L

Peak/ Max Day Demand
 Metered Estimated

Peak Hourly Flow
 Metered Estimated

Note:
This is not the same information sent to the Groundwater section for the Manitoba Government for annual water usage.

Additional comments:

Checklist: Hauled Water (HAUL)

Section 8: HAUL System - General Information

Is your system currently under a drinking water advisory? Yes No N/A

If yes, what type of advisory? (i.e. Boil Water, Water Quality - Arsenic). Type:

If yes, when was it issued? Date:

If the system is under an advisory, are water users notified and public areas posted with the advisory notice? Yes No N/A

Are all water system components adequately protected from vandalism? Yes No N/A

Does the system experience frequent water outages due to equipment failures or water supply capacity issues? Yes No N/A

Is the water system equipped with flow meters to monitor total water use for the system as a whole? Yes No N/A

System able to meet peak water demands with adequate at-tap pressures? Yes No N/A

Does the system receive frequent or repeated complaints from water users about water quality? Yes No N/A

Was the system designed by a Professional Engineer? Yes No N/A

Was the system approved by the Office of Drinking Water? Yes No N/A

Owner/ operator aware of the need to obtain approval (i.e. permit) before significant alterations to the system? This includes watermain extensions. Yes No N/A

Any changes, upgrades, or expansions to the system since the last assessment? Yes No N/A

If yes, explain:

What is the average age (years) of the following components of the system?

Distribution

At inspection time, were all water system components in good working order? Yes No N/A

If no, explain:

Additional comments:

Checklist: Hauled Water (HAUL)

Section 9: HAUL System - Specific only to HAUL Systems

Is the hauled water from a licensed system and approved by the Drinking Water Officer? Yes No N/A

Does the water carry a disinfectant (chlorine) residual at the time of delivery? Yes No N/A

If yes, is the disinfectant (chlorine) residual tested and recorded at the time of delivery? Yes No N/A

Is rechlorination required for the hauled water by the Office of Drinking Water? Yes No N/A

Name company/ organization delivering water:

How often are the tank/s re-filled?

Is the fill connection hose located within a locked building or locked box, or is the connection locked to prevent/ limit access? Yes No N/A

When the hauled water tank/s are being filled, is the fill supervised with health and safety procedures to prevent accidents? Yes No N/A

Checklist: Hauled Water (HAUL)

Section 10: HAUL System - Treated Water Storage in Aboveground Tank(s)

Section is Not Applicable to this System.

What is the total volume of the tank/s? Units.

How many tanks? List # and each volume.

What is the total volume of the tank/s based on the lowest operating level? Units.

Are the tanks in series (flow through one to another) or parallel (separate flows)?

single (1) tank multiple tanks tanks in series tanks in parallel N/A

What is the tank material? polyethylene (PE) fibreglass (FRP)
 epoxy-coated steel other:

Is the tank material or interior tank coating certified or approved for use in a potable water system? (i.e. NSF 61 or FDA approved) Yes No N/A

What is the purpose of the water storage? to meet peak demands
Check all that apply. fire protection other

Storage tanks sized to meet peak demands? Yes No N/A

What is the peak hourly flow rate? Units.

What is the hydraulic retention time at the estimated peak hourly flow rate when the tanks are at their lowest operating level (atmospheric tanks) or at their normal full volume (pressurized tanks)?
(Divide the volume from above by the peak hourly flow rate from above. Convert to same units.)

Retention time: (i.e. 2.50 hours or 150 minutes)

Are the tanks equipped with level sensors for pump operation? Yes No N/A
 floats pressure sensors ultrasonic sensing system other (contact probes)

Are the tanks accessible for visual inspection? Yes No N/A

Are the tanks equipped with access or inspection hatches? Yes No N/A

Are the tanks regularly inspected? Yes No N/A

Last inspected or inspection frequency:

Are the tanks regularly cleaned and disinfected? Yes No N/A

Last cleaned or cleaning frequency:

Checklist: Hauled Water (HAUL)

Section 10: HAUL System - Treated Water Storage in Aboveground Tank(s)

Section is Not Applicable to this System.

Are the inlet and outlet pipes located to minimize the chance of water short-circuiting through the tanks and leading to water stagnation? Yes No N/A

Is the pump intake line properly sealed and located at least 150 mm (6 inches) above the bottom of the tank? Yes No N/A

Can individual tanks be isolated for inspection or maintenance?; without interrupting water service or interrupting chlorine contact time. Yes No N/A

Are pumps connected to multiple tanks to allow for isolation? Yes No N/A

Are all openings sealed watertight? Yes No N/A

Are all vents, overflows, and drain lines equipped with screens? Yes No N/A

Are all vents, overflows, and drain lines located to avoid backflow or run-off? Yes No N/A

If the tanks are located outside the building:

Are the tanks protected from vandalism (fenced area or locked hatches)? Yes No N/A

Are the tanks protected from direct sunlight (opaque or covered?) Yes No N/A

What is the average age (years) of the storage equipment?

Storage

What is the general condition of the storage equipment? Good
 Fair - nearing end of useful life
 Poor - replacement required

Additional comments:

Checklist: Hauled Water (HAUL)

Section 11: HAUL System - Treated Water Storage Inground Reservoir or Buried Tank(s)

Section is Not Applicable to this System.

What type of storage system is used to store treated water before it is distributed?

inground concrete reservoir buried tank/s other:

What is the total volume of the reservoir/s or tank/s? Units.

How many reservoir cells or tanks? List # and each volume.

What is the total storage volume based on the lowest operating level? Units.

Are the cells or tanks in series (flow through one to another) or parallel (separate flows)?

single (1) cell multiple cells cells in series cells in parallel N/A

What is the reservoir or tank material? concrete fibreglass (FRP)
 polyethylene (PE) other:

Is the reservoir or interior tank coating certified or approved for use in a potable water system? (i.e. NSF 61 or FDA approved) Yes No N/A

What is the purpose of the water storage? to meet peak demands
Check all that apply. fire protection other

Reservoir or tanks sized to meet peak demands? Yes No N/A

What is the peak hourly flow rate? Units.

What is the hydraulic retention time at the estimated peak hourly flow rate when the cells/ tanks are at their lowest operating level?

(Divide the volume from above by the peak hourly flow rate from above. Convert to same units.)

Retention time: (i.e. 2.50 hours or 150 minutes)

Is the reservoir or tanks equipped with level sensors for pump operation? Yes No N/A

floats pressure sensors ultrasonic sensing system other (contact probes)

Are the cells or tanks accessible for visual inspection? Yes No N/A

Are the cells or tanks equipped with access or inspection hatches? Yes No N/A

Checklist: Hauled Water (HAUL)

Section 11: HAUL System - Treated Water Storage Inground Reservoir or Buried Tank(s)

Section is Not Applicable to this System.

Are the cells or tanks regularly inspected? Yes No N/A

Last inspected or inspection frequency:

Are the cells or tanks regularly cleaned and disinfected? Yes No N/A

Last cleaned or cleaning frequency:

Are the inlet and outlet pipes located to minimize the chance of water short-circuiting through the cells or tanks and leading to water stagnation? Yes No N/A

Are there at least two isolatable cells or tanks with a valved interconnection? Yes No N/A

Can individual cells or tanks be isolated for inspection or maintenance?; without interrupting water service or interrupting chlorine contact time. Yes No N/A

Is pumping capacity available in at least two cells or tanks to allow water supply to be maintained when cleaning the reservoir cells or tanks? Yes No N/A

Are access hatches curbed and sealed watertight? Yes No N/A

Are all openings sealed watertight? Yes No N/A

Are pipe entries into the reservoir or tanks sealed watertight to prevent contamination? (i.e. LinkSeal or cast-in-place sleeve) Yes No N/A

Do any floor drains or wastewater pipes pass over or through the reservoir? Yes No N/A

Yes - floor drain Yes - wastewater Yes - other

If yes, are these pipes encased in concrete? Yes No N/A

Are pipes through walls protected from differential settling? (i.e. flexible joints/ ball-and-socket joints) Yes No N/A

Are all vents, overflows, and drain lines equipped with screens? Yes No N/A

Is the reservoir or tank equipped with a screened air vent? (i.e. gooseneck or inverted J-pipe) Yes No N/A

Is the reservoir or tank equipped with an adequately sized screened overflow that discharges to the ground? Yes No N/A

Are all vents, overflows, and drain lines located to avoid backflow or run-off? Yes No N/A

Is the reservoir or tank protected from contamination from run-off or spills into the building? Yes No N/A

Is the reservoir or tank located at least 15 m away from sewer system components such as sewer lines or holding tanks? Yes No N/A

If the reservoir extends beyond the footprint of the building, is the reservoir roof adequately sloped and drained? Yes No N/A

Is the reservoir or tank site graded to drain away? Yes No N/A

If the cells or tanks are located outside the building:

Are the cells or tanks protected from vandalism (fenced area or locked hatches)? Yes No N/A

Checklist: Hauled Water (HAUL)

Section 11: HAUL System - Treated Water Storage Inground Reservoir or Buried Tank(s)

Section is Not Applicable to this System.

What is the average age (years) of the storage equipment?

Storage

What is the general condition of the storage equipment?

Good

Fair - nearing end of useful life

Poor - replacement required

Additional comments:

Checklist: Hauled Water (HAUL)

Section 12: HAUL System - Chlorination (Rechlorination)

Section is Not Applicable to this System.

What type of chlorine solution is used? Sodium hypochlorite fed directly from container
 Diluted sodium hypochlorite
 Solution from calcium hypochlorite powders or tablets
 Unscented household bleach
 On-site sodium hypochlorite generation ("analyte")

What is the make-model-brand name of the chlorine or generator used? (i.e. supplier label)

Does the chlorine solution, or powder/ tablets, or salt carry NSF 60 certification? Yes No N/A

Does the on-site sodium hypochlorite generator carry NSF 60 certification? Yes No N/A

Does the on-site sodium hypochlorite generator carry NSF 61 certification? Yes No N/A

Is an adequate amount of chlorine chemical kept on-hand at all times? (i.e. 30 days minimum) Yes No N/A

Is the chlorine solution stored away from sunlight? Yes No N/A

Is the sodium hypochlorite solution used within 3 months of purchase? Yes No N/A

Are chlorine tanks stored over a spill tray? Yes No N/A

Is the chlorine stored in a separate chemical storage room? Yes No N/A

Is the system equipped with duty-standby chlorine pumps with automatic switchover in the case of pump failure? Yes No N/A

Is there only a single feed chlorine pump? Yes No N/A

Is there a spare feed chlorine pump? (i.e. "shelf spare") Yes No N/A

Are critical spare parts kept on-hand to maintain the feed pump? Yes No N/A

What triggers operation of the chlorine feed? (i.e. reservoir level, etc...)

Is operation of the feed pump controlled by the distribution pump (fixed injection rate) or by a flow meter (flow-paced injection rate)?

N/A Distribution pump Flow meter Other

Do feed pump settings suggest a properly sized feed pump? Yes No N/A

What type of chlorine residual test kit is used?

N/A Digital DPD colorimeter Colour wheel Unapproved unit (i.e. pool kit)

Is the system equipped with an online chlorine residual analyzer? Yes No N/A

Explain where the analyzer sample draw water goes:

Normally, what is the free chlorine residual (mg/L) of the outgoing water?

Checklist: Hauled Water (HAUL)

Section 12: HAUL System - Chlorination (Rechlorination)

Section is Not Applicable to this System.

What is the average age (years) of the chlorination equipment?

Chlorination

What is the general condition of the chlorination equipment? Good

Fair - nearing end of useful life

Poor - replacement required

Additional comments:

Checklist: Hauled Water (HAUL)

Section 13: HAUL System - Distribution System (not intended for a building plumbing system)

Are there up-to-date maps of the distribution system indicating locations of:
service connections, valves, flush-outs, hydrants, etc... Yes No N/A

What types of watermain materials exist in the distribution system? Check all that apply.

- PVC (polyvinyl chloride) AC (asbestos cement) iron - cast
 HDPE (high-density polyethylene) other iron - ductile

Are watermains adequately sized?
(i.e. 50 mm (2 inch) if no fire protection, 150 mm (6 inch) if fire protection) Yes No N/A

Are watermains adequate pressure rating?
(i.e. minimum 100 psi or 690 kPa) Yes No N/A

Is adequate at-tap pressure of 30-to-60 psi (200-to-400 kPa) maintained
in the distribution system at all times? Yes No N/A

Does the system have a watermain replacement or renewal strategy? Yes No N/A

Are a set of standards available for new construction?;
reference to Manitoba Water Services Board (MWSB) or
City of Winnipeg standard construction specifications or similar,
to ensure proper materials and construction procedures are followed? Yes No N/A

Have minimum design and construction standards been established for
new service connections? Yes No N/A

Is all new construction inspected to meet these requirements? Yes No N/A

Are all new watermains, service lines, and related equipment CSA or NSF
certified for use in potable water systems? Yes No N/A

Are all new watermains and water lines disinfected as per AWWA, MWSB,
or City of Winnipeg disinfection standards including
confirmatory bacterial testing before placed into service? Yes No N/A

If piped sewer is present, is there at least 3 m (10 feet) horizontal distance
separation between watermains and sewer mains, where they run parallel? Yes No N/A

If watermains are closer than 3 m (10 feet) from sewer mains
are the watermains vertically above the sewer mains? Yes No N/A

If yes, do the watermains have a vertical distance separation at least
0.45 m (18 inches)? Yes No N/A

If watermains cross: sewer mains, raw or other non-potable water lines,
oil or gas pipelines, etc... is the watermain above at least 0.45 m (18 inches)? Yes No N/A

Are watermains protected from damage by being buried with at least
2.4 m (8 feet) cover for year-round systems or 0.45 m (18 inches) for seasonal? Yes No N/A

Has the distribution system had any issues with frozen service lines? Yes No N/A

Are "bleeder" lines or valves used to prevent frozen service lines?
(These are used in some northern communities.) Yes No N/A

Checklist: Hauled Water (HAUL)

Section 13: HAUL System - Distribution System (not intended for a building plumbing system)

Are water service connections metered?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
	<input type="checkbox"/> some connections
Are water losses kept under 15% to reduce water production requirements?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
	<input type="checkbox"/> don't know
What is the estimated % of water loss for this water system?	% <input type="text"/> <input type="checkbox"/> don't know

Are dead ends supplied with hydrants or flush-outs?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Are valves and hydrants regularly inspected and exercised?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Are there adequate number of valves, hydrants, and flush-outs to isolate and flush the system? Drain the system if seasonal.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Are watermains and distribution lines flushed at least annually?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Flushing frequency:	<input type="text"/>

Are there any known lead service lines present in the system?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
	<input type="checkbox"/> don't know
If found, has a strategy been developed to remove lead service lines?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Is there a cross connection and backflow prevention program?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Are connections where there is potential for backflow of hazardous materials protected by backflow prevention assembly or air gap? (i.e. potential locations include agricultural operations, wastewater treatment plants, etc.)	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Are connections from heat exchangers prohibited from being connected to the water supply? (i.e. prohibited from returning water to the potable water line)	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Is there equipment within the distribution system with a high water table or potential to be flooded?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Includes: manholes with potable water equipment, underground meter/ valve pits	
Are all manholes with potable water equipment or underground meter/ valve pits or similar installations, watertight and free from non-potable water intrusion?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Are air relief valves within the distribution system located aboveground?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A

Checklist: Hauled Water (HAUL)

Section 13: HAUL System - Distribution System (not intended for a building plumbing system)

Are there periodic changes in treated water quality in the distribution system? Yes No N/A

Do the distribution system bacterial records suggest it is well operated and well maintained? Yes No N/A

Do the distribution system chlorine residual records suggest it is well operated and well maintained? Yes No N/A

Do the records suggest any specific water quality issues? Yes No N/A

If yes, please explain:

What is the average age (years) of the distribution system?

Distribution

What is the general condition of the distribution system? Good
 Fair - nearing end of useful life
 Poor - replacement required

Additional comments:

Checklist: Hauled Water (HAUL)

Section 14: HAUL System - Operation and Maintenance (O&M)

- Is the water system checked on a daily basis when it is operating? Yes No N/A
- Has the water distribution system been classified under the operator certification program? Yes No N/A
- water distribution system: small system 1 2 3 4
- Have any operators been classified under the operator certification program? Yes No N/A
- Is there a back-up operator for the water system? Yes No N/A
- How many hours per day does the operator spend on the water system?
- Is there an up-to-date emergency contact list? Yes No N/A
- Is there a list of critical water users (i.e. hospitals, personal care homes, schools) to be contacted during an emergency? Yes No N/A
- Is there a procedure for emergency notification of water users if there is a supply interruption or water quality issue or an advisory? Yes No N/A
- Is there a plan for obtaining water on an emergency basis? Yes No N/A
- If the system is operated on a seasonal basis, are Office of Drinking Water procedures followed for start-up and shut-down of the water system? Yes No N/A
- Have written procedures been developed for key activities such as: watermain repairs, flushing, etc? Yes No N/A
- Is there an up-to-date water system drawing available? Yes No N/A
- Is there a maintenance log for recording preventive maintenance, repairs, etc? Yes No N/A
- Are water system records kept for a minimum of 2 years? Yes No N/A
- Are instruments regularly calibrated, in particular, water testing equipment to ensure reliable test results? Yes No N/A
- Are extra bacterial sample bottles kept on-hand for emergency purposes? Yes No N/A
- Is the system in compliance with the sampling parameters and frequency listed in the Operating Licence? Yes No N/A

Additional comments: